



Water Truck Inspection Form

Lewiston Orchards Irrigation District
1520 Powers Ave., Lewiston, Idaho 83501

Tel: 208-746-8235
Fax: 208-746-6484

IF FIRE HYDRANT METER IS NEEDED YOU MUST FILL OUT A FIRE HYDRANT CONSTRUCTION ACCESS PERMIT APPLICATION

PLEASE FILL OUT ONE FORM PER TANK INSPECTION

Meters are available for pickup between 7am to 2pm M-F with 24 hour notice.

**Fields Required Requestors Information

****Requested Inspection Date:** ****# of Tanks:**

****Company Name:**

****Billing Address:**

****Physical Address:**

****City:** ****State:** ****Zip Code:**

****Contact Person:**

****Phone No.:** **Alt. Phone No.:**

Bulk Tank Filling Conditions

1. All tanks must display a current inspection sticker.
2. When filling a top fill tank **with** permanently mounted piping, the outlet pipe must be properly air gapped.
3. When a top fill tank **without** permanently mounted piping is filled through a hose, the hose outlet must be equipped with a permanent air gap fitting.
4. When a tank is filled with a 1-inch or smaller hose, a hose bibb vacuum breaker must be attached to the discharge end of the hose.
5. Bottom fill tanks must be properly equipped with an approved Reduced Pressure Backflow Assembly (RPBA). The RPBA must be tested by a qualified tester annually with the test results sent to the Lewiston Orchards Irrigation District annually or the permit will be canceled.

Please direct all questions regarding backflow prevention and air-gaps to the L.O.I.D. Backflow Prevention Specialist, Matt Baker at (208) 305-5398.

To be completed by L.O.I.D. Personnel Only

Time of inspection: _____

RESULTS: FAILED APPROVED

Inspected by: _____

REMARKS: _____

Accepted by: _____ Date: _____

TYPE OF BACKFLOW PROTECTION:
 AIR GAP HOSE END AIR GAP RPBA